

THE GRADE OF STATION FOOTPRINT IS TO BE FLUSH WITH SIDEWALK UP TO 5' PAST THE INLET & OUTLET FIRE VALVES

TREES TO BE REMOVED

PROPOSED RETAINING WALL
(4' T x 1' W x 100' L)

FACILITIES DIMENSIONS
MONITOR VAULT: 11' x 7'
REGULATOR VAULT: 9' x 7'
SCADA CABINET: 2.5' W x 41' x 9' T
CONCRETE PAD: 50' x 11'

NEW 6" PL HP - 16'

















NEW 6" PL HP

TRENCH & PAVING NOTES
- PG# E TO TRENCH ACROSS EX. SIDEWALK & GUTTER
- PG# E TO RESTORE BOTH SIDEWALK & GUTTER BACK TO MATCH EXISTING CONDITION


















93'

LEGEND (PG 2)

EXISTING

	GAS MAIN (SIZE & PRESSURE AS NOTED)
	GAS MAIN TO BE C/O (SIZE & PRES AS NOTED)
	PROPERTY LINE
	FACE OF CURB, EDGE OF CURB
	BACK OF SIDEWALK
	PG&E EASEMENT
	WATER
	SEWER
	STORM DRAIN
	COMM (PHONE / CABLE)
	ELECTRIC (UNDERGROUND)
	FENCE
	TREE
	STREET LIGHT POLE
	UNDERGROUND ELECTRICAL VAULT
	STORM DRAIN

INSTALL

	GAS MAIN (TP)
	GAS MAIN (HP)
	PG&E ELECTRIC (SCADA)
	TRENCH IDENTIFIER
	FIRE VALVE
	SOLAR POLE
	SCADA RTU CABINET (PAD)
	FLANGED TEE, TOP TAP
	PRESSURE CONTROL FITTING
	REGULATOR VAULT
	MONITOR VAULT
	VAULT VENT
	ETS STATION
	TRANSITION FITTING
	ELECTRONIC MARKER BALL
	REDUCER
	90° ELBOW